

09/30/22

The proposed zoning case must address the comments listed below by prescriptive code or equivalency, as approved by the Cobb County Fire Marshal's Office

FIRE DEPARTMENT ACCESS:

Provide emergency access through all gates securing Fire Dept. access with a minimum 12'-0" clear width and approved means of operation (www.knoxbox.com)

Jeff Byrd

(770) 528-8814

Jeffrey.byrd@cobbcounty.org