

Please find attached the entrance plan revised per comments. Comments have been addressed as follows:

1. Provide height of brick wall section. The brick wall is 8' high. This is labeled at each of the walls.
2. Provide height of brick columns. The brick columns are 7' wide x 7' wide x 10' high. This is labeled at each of the columns.
3. Provide height of metal fence section and submit visual. The metal fence is 6' high. This is labeled at the fence. A visual of the fence has been added to the lower, left of the sheet.

Please let me know if there are any more questions. Also, I submitted the full LDP plan set with the gates added. Will there be a separate review for those or once the Mayor and Council approves the plan are the LDP plans ready for approval?