

06/20/25

Water comments:

At development:

☐ YES☒ NO

Fire flow test required:

☒ YES☐ NO

Size and location of existing water main(s): 12" in Powder Springs Dallas Rd ROW

Additional water comments:

Sewer comments:

In the drainage basin:

☒ YES☐ NO

At development:

☒ YES☐ NO

Approximate distance to nearest sewer: North of site approximately 400 feet away

Estimated waste generation (in G.P.D.): Average daily flow = 62,400

Peak flow = 156,000

Treatment plant: South Cobb WRF

Plant capacity:

☒ Yes☐ NO

Projected plant availability:

☐ 0-5 years☒ 5-10 years☐ over 10 years

Off-site easement required:

☒ YES*☐ NO

Line capacity study required:

☐ YES☒ NO

Letter of allocation issued:

☐ YES☒ NO

Septic tank recommended by this department:

☐ YES☒ NO

Subject to Health Department approval:

☐ YES☒ NO

*If off-site easements are required, the developer/owner must submit easements to CCWS for review and approval as to form and stipulations prior to the execution of easements by the property owners. All easement acquisitions are the responsibility of the developer/owner.

Additional sewer comments:

Note: These comments only reflect what facilities were in existence at the time of this review. Developer may be required to install/upgrade water mains based on fire flow test results or Fire Department code. This will be addressed in the Plan Review process. The developer/owner will be responsible for connecting to the existing county water and sewer systems, installing and/or upgrading all outfalls & water mains, obtaining onsite and/or offsite easements, and dedication of onsite and/or offsite water and sewer to Cobb County as may be required. Rezoning does not guarantee water/sewer availability or capacity unless so stated in writing by the Cobb County Water System.